

Olympia Electronics fire suppression panel



ERP : 103-023-627

● TECHNICAL SPECIFICATIONS

- EN12094-1 certified.
- The panel is delivered with connected supply wires and detection cables.
- Butane or gas detectors can be connected to one of the panels' zones and a command can be given to the electrovalve of the gas supply system.



info@flamecontrol.gr

www.flamecontrol.gr

FLAMECONTROL

20 Sokratous St. Metamorfosi, 14451, Attica

T: +30 210 6208 500